

Versa-Sense™ II Electronic Leak Detector

VS

SPECIFICATIONS

115 Volt Units

Power Supply: 100 VAC or 110-120VAC, 50 Milliamp, Current Draw

Output Supply: 110-120VAC, 100 Watt Power, Maximum (1 Amp)

220Volt Units

Power Supply: 220-240VAC, 25 Milliamp, Current Draw


Output Supply: 220-240VAC, 100 Watt Power, Maximum (.5 Amp)

ITEM PART DESCRIPTIONS AND PART NUMBERS

P29-800TF10 Electronic Leak Detector W/ 10' Leads and PTFE Probes

P29-800 Electronic Leak Detector (Unit Only)

P29-804 10' Lead and PTFE Probe (Two Required Per Unit)



VERSA-SENSE II Electronic Leak Detector

The VERSA-SENSE II Electronic Leak Detector consists of a modular control unit encased in a watertight enclosure and two detection probes. All of these items are wired together as noted on the schematic illustration Figure A and Figure D.

The VERSA-SENSE II Electronic Leak Detector senses pumped liquid entering the air chambers of the pump and works on the principle of conductance. The probes are installed into the bottom boss on the air chambers (E1, E4, E2, E3, and U2 pump models.) When the diaphragm fails, the probe is exposed to the pumped liquid. This produces a low current change of 1.2 volts DC (<1 milliamp) which signals the control unit. One of the two indicator lights signal which diaphragm has failed, and which air chamber has been contaminated by pumped fluid.

NOTE: The VERSA-SENSE II Leak Detector will detect any moisture that pools at the bottom of the air chamber. Air supplies with high moisture content will deposit the moisture at the bottom of the pump's inner chamber. This will cause the probe to send false signals of diaphragm rupture to the control unit. When the leak detector is used to detect diaphragm failure it is recommended that an air line dryer be installed in the air line supply line to lessen the chance of false signals.

⚠ WARNING



Hazardous voltage. This Leak Detector is an electrical device. It should be wired by only qualified, licensed electricians. The cover should never be removed except by authorized, licensed electricians. Failure to heed this warning may result in electric shock, personal lasting injury or death.


Power shall be disconnected before enclosure is opened.

Enclosure shall be closed before power is restored.

Probe Installation


To install the probe, first back-twist the cable counterclockwise to avoid wire twist when the probe is threaded clockwise into the 1/4" NPT boss ports. Apply PTFE tape or a small amount of thread sealant to the threads prior to insertion.

WIRING ILLUSTRATION
Figure A



Options

The control unit can be easily wired to an audible alarm or pump shutdown device. For example you can connect the leak detector unit to a solenoid, which can shut the air supply off to the pump, or sound an alarm by routing the external device into the leak detector unit. The wires can enter through one of the three port holes in the leak detection unit. The output connection terminal has 100 watt power output and each chamber has independent connections. If combining the two chambers, a four wire lead spliced before the external device would be necessary (See output connection terminal Figure B.)




Conductivity

The leak detector probes work under the principle of conductance. Not all pumped liquid is conductive. If the diaphragm fails, the pumped product will conduct (complete the circuit) and signal the box and the warning light will come on.

Sensitivity of the detector can be adjusted by the adjusting knobs R5 and R6. (See Figure C.) These adjustment knobs work independently for each side (chamber). They can be moved with a small screw driver. These sensitivity knobs are also important in setting to detect conductance fluid at the sensitivity most required. The sensitivity range of the detector is adjustable from OHM (2,000 Micro MHO) to 100,000 OHM (10 Micro MHO).

When sensing low conductivity, turning the screws clockwise increases probe sensitivity.



Conductive/Non-Conductive Switch Information

Note: Pumps containing driver fluid should be filled with conductive or non-conductive fluid, depending on the fluid pumped. The driver fluid should be opposite of the pumped product in order to determine diaphragm failure and light warning LED signal(s). This is adjusted inside the box in the following manner:

SW1 DOWN (LED 1) = LED on w/presence of conductive fluid and off w/absence of conductive fluid.

SW1 UP (LED 1) = LED on w/absence of conductive fluid and off w/absence of conductive fluid.


— OR —

SW2 DOWN (LED 2) = LED on w/presence of conductive fluid and off w/absence of conductive fluid.

SW2 UP (LED 2) = LED on w/absence of conductive fluid and off w/absence of conductive fluid.

Versa-Sense II Schematic

WIRING ILLUSTRATION
Figure D



⚠ CAUTION ⚠

FOR 220 VOLT UNITS:
Plug in only to 220 volt systems. Do not have power to the cord (do not have it plugged in) when connecting to the box terminals.

⚠ CAUTION ⚠

FOR 115 VOLT UNITS:
Plug in only to 100 volt systems. Do not have power to the cord (do not have it plugged in) when connecting to the box terminals.

Versa-Matic® and Versa-Sense™ are registered tradenames and trademarks of IDEX Corporation.

VERSAMATIC® PUMP COMPANY
A Unit of IDEX Corporation
6017 Enterprise Drive
Export, PA 15632-8969
(724) 327-7867
Fax: (724) 327-4300
www.versamatic.com



©2008 IDEX Corporation



VMVSIOM-208